



Compliant Datasheets

Compliant Wet Pour on to New Base

STANDARD BASE DETAILS - OVERALL MINIMUM 40mm DEPTH

New Base Construction (assuming reasonable draining sub-soil)

1. Excavate existing concrete / tarmac / grass base to minimum depth of selected thickness of **COMPLIANT WET POUR** plus 100mm.
2. Standard edge detail is to supply and install well haunched 50mm x 150mm precast concrete edgings. Haunching must be below the base level of the **COMPLIANT WET POUR** surface. Alternatives available included pressure treated timber of a minimum size of 25mm x 150mm, firmly fixed with suitable pegs at 1 metre centres.
3. Supply, lay and lightly compact to a minimum finished depth of 100mm, M.O.T. Type 1 foundation stone. Care must be taken to ensure that the correct depth remains, particularly at the edges for selected depth of **COMPLIANT WET POUR**, and that the stone is compacted right up to the kerbing. Levels should be to a tolerance under a metre straight edge of not greater than 10mm. There must be no loose stone lying on or over the general surface level.
4. Reinstate where necessary, if and as agreed.
5. Remove all spoil material from site, clean up, leaving site neat and tidy.
6. Base is now ready to accept our **COMPLIANT WET POUR** Impact Absorbing Surfacing.

In accordance with the Company's policy of continuous development, Boyd Sport & Play Ltd t/as sportsequip.co.uk reserve the right to alter or amend specifications without prior notice. All statements in this datasheet are made in good faith but the Company will not be held responsible for any consequence arising out of errors or omissions.

sportsequip.co.uk

The Manor, Tur Langton, Leicestershire, LE8 0PJ

t: 01858 545789 | f: 01858 545890 | e: info@sportsequip.co.uk

sportsequip.co.uk and Astroturf® are registered trademarks © sportsequip.co.uk 2013

